



GOVT. OF ASSAM

OFFICE OF THE JOINT DIRECTOR OF HEALTH SERVICES :: DIBRUGARH  
DISTRICT DIBRUGARH

No. 14/2024

Dated Dibrugarh the 22/10/24

**HYGIENIC AND SANITATION**

Certified that the Hygienic and Sanitation conditions in respect of **Nurture International School**, Kadomoni, Dibrugarh is found to be satisfactory as per Inspection report received. This certificate is valid for one year w.e.f. 22/10/2024 to 21/10/2025.

Dated Dibrugarh the 22/10/2024

Sub-Divisional Medical & Health Officer (PH)  
O/o the Jt. Director of Health Services,  
Dibrugarh

~~Sub-Divisional Medical & Health Officer (PH)~~  
~~O/o Jt. D H S, Dibrugarh~~





**WATER ANALYSIS REPORT**

Sample ID	DIB/DLL/2024-25/3053	Issue Date	23/10/2024
Issued to	Nurture international School	Sample Received Date	18/10/2024
Pin point	K.C. Gogoi path, Dibrugarh	Block	N/A
GP	N/A	Village	K.C. Gogoi path, Dibrugarh
Type of Source	Filter Water	Source Installed	Self
Quantity	1000 ml	Sample Collected On	18/10/2024
Date of Analysis Started	18/10/2024	Date of Analysis Completed	21/10/2024

Sl. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence of better alternate source)	
<b>PHYSICAL TEST</b>						
1	pH	IS: 3025: Part 11	6.78	6.5 - 8.5	No relaxation	pH Units
2	TDS	IS: 3025: Part 16	126	500	2000	mg/L
3	Turbidity	IS: 3025: Part 10	0.8	1	5	NTU
4	Colour	IS: 3025: Part 4	<5	5	15	Hazen
<b>CHEMICAL TEST</b>						
5	Chloride	IS: 3025: Part 32	17.01	250	1000	mg/L
6	Total Hardness	IS: 3025: Part 21	90	200	600	mg/L
7	Total Alkalinity	IS: 3025: Part 23	75	200	600	mg/L
8	Calcium	IS: 3025: Part 40	28.05	75	200	mg/L
9	Magnesium	APHA-3500- Mg B	<5	30	100	mg/L
10	Iron	APHA-3500-Fe B	0.08	1	No Relaxation	mg/L
11	Nitrate	APHA-3500- Fe B	1.88	45	No Relaxation	mg/L
12	Sulphate	APHA-4500- SO <sub>4</sub> E	2.09	200	400	Mg/L
13	Fluoride	APHA 4500 NO <sub>3</sub> B	0.08	1	1.5	mg/L
14	Arsenic	IS:3025: Part 37	<0.009	0.01	No Relaxation	mg/L
<b>BACTERIOLOGICAL TEST</b>						
15	Bacteria	H <sub>2</sub> S Vial	Absent	No Relaxation	No Relaxation	

Remarks:-Analysed parameters were found within the permissible limit & safe for drinking.

Asst. Commissioner (DLL)  
 PHE, Dibrugarh

\*\*\*\*\*END OF THE REPORT\*\*\*\*\*